



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599  
[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

## NOTICE OF ACCEPTANCE (NOA)

Mid-States Asphalt & Cant Strip, Inc.  
1637 51<sup>st</sup> Avenue  
Tuscaloosa, AL 35401

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: MSA - BUR Systems over Steel Decks.

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state, model/ series and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 11-0104.07 and consists of pages 1 through 12.

The submitted documentation was reviewed by Gaspar J Rodriguez.



NOA No: 15-0406.07  
Expiration Date: 02/09/17  
Approval Date: 01/28/16  
Page 1 of 12

## ROOFING SYSTEM APPROVAL

**Category:** Roofing  
**Sub-Category:** Built-Up Roofing  
**Material:** Fiberglass  
**Deck Type:** Steel  
**Maximum Design Pressure:** -45 psf

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

Product	Dimensions	Test Specification	Product Description
Arrowglass Base	36" x 108'	ASTM D 4601 Type II	A non-porous 28 pound base sheet consisting of a heavyweight, fiberglass mat saturated with type IV asphalt with a sand surfacing. For use as a mechanically fastened or adhered base sheet in a wide variety of built-up roofing applications.
MSA MG2 Base Sheet	36" x 108'	ASTM D 4601 Type II	A non-porous 28 pound base sheet consisting of a heavyweight, fiberglass mat saturated with polymer modified asphalt with a sand surfacing. For use as a mechanically fastened or adhered base sheet in a wide variety of built-up roofing applications.
MSA Ply 4	36" x 180'	ASTM D 2178 Type IV	A heavyweight fiberglass mat saturated with type IV asphalt, giving excellent strength and weathering characteristics. For use as a ply sheet in hot mopped built-up roofing applications
MSA Ply 6	36" x 180'	ASTM D 2178 Type VI	A heavyweight fiberglass mat saturated with type IV asphalt, giving excellent strength and weathering characteristics. For use as a ply sheet in hot mopped built-up roofing applications



NOA No: 15-0406.07  
Expiration Date: 02/09/17  
Approval Date: 01/28/16  
Page 2 of 12

## APPROVED INSULATIONS:

TABLE 2

<u>Product</u>	<u>Product Description</u>	<u>Manufacturer</u> (With current NOA)
ACFoam II	Polyisocyanurate foam insulation	Atlas Energy Products
ACFoam Composite	Composite Insulation board	Atlas Energy Products
ISO 95+ GL	Polyisocyanurate foam insulation	Firestone Bldg. Products
ISO 95+ Composite	Composite Insulation board	Firestone Bldg. Products
EnergyGuard Perlite Recover Board, EnergyGuard Perlite	Rigid perlite roof insulation board	GAF Material Corp.
EnergyGuard High Density Fiberboard	High Density Wood Fiber board	GAF Material Corp.
ENRGY-3	Polyisocyanurate foam insulation	Johns Manville Corp.
ENRGY 3 Plus, Fesco Foam	Polyisocyanurate / woodfiber insulation	Johns Manville
ENRGY-3 Composite	Composite Insulation board	Johns Manville Corp.
Fesco Board, Retro-Fit Board	Rigid perlite roof insulation board	Johns Manville Corp.
DensDeck®	Water resistant gypsum board	G-P Gypsum Corp.
Thermarroof Composite-3	Composite Insulation board	RMax
Multi-Max FA-3	Polyisocyanurate foam insulation	RMax



**APPROVED FASTENERS:****TABLE 3**

<b>Fastener Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Dimensions</b>	<b>Manufacturer (With Current NOA)</b>
1.	Dekfast Stainless Steel #12 Fasteners	Insulation fastener for wood, steel and concrete decks	Various	SFS Intec.
2.	Dekfast Stainless Steel #12 DP Fasteners	Insulation fastener for wood, steel and concrete decks	Various	SFS Intec.
3.	Dekfast Stainless Steel #14 Fasteners	Insulation fastener for wood, steel and concrete decks	Various	SFS Intec.
4.	Dekfast #12 Fasteners	Insulation fastener for wood, steel and concrete decks	Various	SFS Intec.
5.	Dekfast #14 Fasteners	Insulation fastener for wood, steel and concrete decks	Various	SFS Intec.
6.	Dekfast #15 HS Fasteners	Insulation fastener for wood, steel and concrete decks	Various	SFS Intec.
7.	Dekfast #12 Hex Fasteners	Insulation fastener for wood, steel and concrete decks	Various	SFS Intec.
8.	Dekfast Autoset Plate	Galvalume stress plate.	2 7/8" x 3 1/4"	SFS Intec.
9.	Dekfast Round Plate	Galvalume stress plate.	3"	SFS Intec.
10.	Dekfast Lock Plate	Polypropylene stress plate.	3" x 3 1/4"	SFS Intec.
11.	Dekfast Hex Plate	Galvalume hex stress plate.	2 7/8" x 3 1/4"	SFS Intec.
12.	Dekfast System ES #12 Steel	Pre-assembled fastener and plate	Various	SFS Intec.
13.	Dekfast System ES #14 Steel	Pre-assembled fastener and plate	Various	SFS Intec.
14.	Firestone All-Purpose Fastener	Insulation and membrane fastener	Various	Firestone Building Products
15.	Firestone HD Fastener	Insulation and membrane fastener	Various	Firestone Building Products
16.	Hexagonal Plate	Insulation attachment hexagonal plate	3 3/8" x 2 7/8"	Firestone Building Products
17.	OMG Stainless #12	Insulation and membrane fastener	Various	OMG
18.	OMG Hex Head #12	Insulation and membrane fastener	Various	OMG
19.	OMG Hex Head #14	Insulation and membrane fastener	Various	OMG
20.	OMG Standard	Insulation and membrane fastener	Various	OMG
21.	OMG Heavy Duty	Insulation and membrane fastener	Various	OMG
22.	OMG #10	Insulation and membrane fastener	Various	OMG

**APPROVED FASTENERS:****TABLE 3**

<b>Fastener Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Dimensions</b>	<b>Manufacturer (With Current NOA)</b>
23.	OMG Iron-Lok or Strap Toggle	Insulation and membrane fastener	Various	OMG
24.	OMG Standard Plate	Galvalume AZ55 stress plate	3" round 3" square	OMG
25.	OMG Plate	Polypropylene stress plate	3" round	OMG
26.	OMG G-2 Plate	3.5" round galvalume AZ55 steel plate	3.5" round	OMG
27.	OMG LGP Plate	Insulation and membrane plate	Various	OMG
28.	Rawl #12 Fastener	Insulation fastener	Various	Powers Fasteners, Inc.
29.	Rawl #14 Fastener	Insulation fastener	Various	Powers Fasteners, Inc.
30.	Rawl Plate	Galvalume AZ50 steel plate	3" round	Powers Fasteners, Inc.
31.	Tru-Fast TP	Insulation and membrane fastener	Various	Tru-Fast Corp.
32.	Tru-Fast Ultra SS	Insulation and membrane fastener	Various	Tru-Fast Corp.
33.	Tru-Fast DL	Insulation and membrane fastener	Various	Tru-Fast Corp.
34.	Tru-Fast DP	Insulation and membrane fastener	Various	Tru-Fast Corp.
35.	Tru-Fast DP-H	Insulation and membrane fastener	Various	Tru-Fast Corp.
36.	Tru-Fast HD	Insulation and membrane fastener	Various	Tru-Fast Corp.
37.	Tru-Fast PA System	Pre-assembled fastener and plate	Various	Tru-Fast Corp.
38.	Tru-Fast MP-3	Stress Plate	3"	Tru-Fast Corp.
39.	Tru-Fast MPH-3	Stress Plate	3"	Tru-Fast Corp.
40.	Tru-Fast Plastic	Stress Plate	3"	Tru-Fast Corp.

**EVIDENCE SUBMITTED:**

<b><u>Test Agency</u></b>	<b><u>Test Identifier</u></b>	<b><u>Description</u></b>	<b><u>Date</u></b>
Factory Mutual Research	3004059	FM 4470	09/23/10
PRI Construction Material Technologies	BWR-506-02-01	ASTM D 2178	01/23/09
	BWR-530-02-01	ASTM D 4601	12/03/10
	BWR-508-02-01	ASTM D 4601	01/23/09
	BWR-505-02-01	ASTM D 2178	01/23/09



NOA No: 15-0406.07  
 Expiration Date: 02/09/17  
 Approval Date: 01/28/16  
 Page 5 of 12

## APPROVED ASSEMBLIES

**Membrane Type:** BUR

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga. steel

**System Type B(1):** Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.

**All General and System Limitations apply.**

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
ENRGY-3 Composite, ENRGY 3 Plus, ACFoam Composite, Thermarroof Composite-3, ISO 95+ Composite, Fesco Foam Minimum 1.5" thick	1, 4, 5, 9, 10, 11, 14, 16, 20, 21, 22, 23, 24, 25, 26, 27, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40	1:2 ft <sup>2</sup>

**Note:** Base layers of insulation shall be mechanically attached using the fastener density listed. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Insulation fasteners shall be tested for withdrawal resistance in compliance with Protocol TAS 105 to confirm compliance with the wind load requirements. Please refer to Roofing Application Standard RAS 117 for insulation attachment..

Top Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
EnergyGuard Perlite, Fesco Board Minimum ¾" thick	N/A	N/A

**Note:** Top layer of insulation shall be adhered with approved hot asphalt, within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as the base layer shall only be used as the base layer with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side face down.

**Base Sheet:** Install One ply of Arrowglass Base or MSA MG2 Base Sheet directly to the insulated substrate with a 4" lap. Adhere in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Ply Sheet:** Two or more plies of MSA Ply 4 or MSA Ply 6 ply sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to the base sheet.

**Surfacing:** Install the following:  
1. Flood coat of hot asphalt at an application rate of 60 lbs./sq.; plus gravel fully embeded at an application rate of 400 lbs./sq.

**Maximum Design Pressure:** -45 psf (See General Limitation #9.)



**Membrane Type:** BUR  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** 18-22 ga. steel  
**System Type B(2):** Base/Intermideate layer of insulation mechanically fastened, top layer adhered with approved asphalt.

**All General and System Limitations apply.**

One or more layers of any of the following insulations:

<b>Base Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>EnergyGuard Perlite, Fesco Board Minimum ¾" thick</b>	N/A	N/A

**Note: Optopnal Base layer of insulation shall be loose laid with preliminary fastening.**

<b>Base/Intermideate Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam II, Multi-Max FA-3, ISO 95+ GL Minimum 1.5" thick</b>	1, 4, 5, 9, 10, 11, 14, 16, 20, 21, 22, 23, 24, 25, 26, 27, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40	1:2 ft <sup>2</sup>

**Note: Base/Intermideate layers of insulation shall be mechanically attached using the fastener density listed. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Insulation fasteners shall be tested for withdrawal resistance in compliance with Protocol TAS 105 to confirm compliance with the wind load requirements. Please refer to Roofing Application Standard RAS 117 for insulation attachment..**

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>EnergyGuard Perlite, Fesco Board Minimum ½" thick</b>	N/A	N/A

**Note: Top layer of insulation shall be adhered with approved hot asphalt, within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as the base layer shall only be used as the base layer with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side face down.**

- Base Sheet:** Install One ply of Arrowglass Base or MSA MG2 Base Sheet directly to the insulated substrate with a 4" lap. Adhere in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Ply Sheet:** Two or more plies of MSA Ply 4 or MSA Ply 6 ply sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to the base sheet.
- Surfacing:** Install the following:  
 1. Flood coat of hot asphalt at an application rate of 60 lbs./sq.; plus gravel fully embeded at an application rate of 400 lbs./sq.

**Maximum Design Pressure:** -45 psf (See General Limitation #9.)



**Membrane Type:** BUR  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** 18-22 ga. steel  
**System Type B(3):** Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.

**All General and System Limitations apply.**

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
ISO 95+ GL Minimum 1.5" thick	14, 16	1:3.2 ft <sup>2</sup>
ISO 95+ GL Minimum 2" thick	14, 16	1:4 ft <sup>2</sup>

**Note:** Base layers of insulation shall be mechanically attached using the fastener density listed. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Insulation fasteners shall be tested for withdrawal resistance in compliance with Protocol TAS 105 to confirm compliance with the wind load requirements. Please refer to Roofing Application Standard RAS 117 for insulation attachment..

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
EnergyGuard Perlite, Fesco Board Minimum ¾" thick	N/A	N/A
DensDeck Minimum ¼" thick	N/A	N/A

**Note:** Top layer of insulation shall be adhered with approved hot asphalt, within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as the base layer shall only be used as the base layer with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side face down.

**Base Sheet:** Install One ply of Arrowglass Base or MSA MG2 Base Sheet directly to the insulated substrate with a 4" lap. Adhere in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Ply Sheet:** Two or more plies of MSA Ply 4 or MSA Ply 6 ply sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to the base sheet.

**Surfacing:** Install the following:  
1. Flood coat of hot asphalt at an application rate of 60 lbs./sq.; plus gravel fully embedded at an application rate of 400 lbs./sq.

**Maximum Design Pressure:** -45 psf (See General Limitation #9.)





**Membrane Type:** BUR  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** 18-22 ga. steel  
**System Type B(4):** Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.

**All General and System Limitations apply.**

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
ACFoam II, Multi-Max FA-3, ISO 95+ GL Minimum 1.5" thick	1, 4, 5, 9, 10, 11, 14, 16, 20, 21, 22, 23, 24, 25, 26, 27, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40	1:2 ft <sup>2</sup>

**Note:** Base layers of insulation shall be mechanically attached using the fastener density listed. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Insulation fasteners shall be tested for withdrawal resistance in compliance with Protocol TAS 105 to confirm compliance with the wind load requirements. Please refer to Roofing Application Standard RAS 117 for insulation attachment..

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
EnergyGuard Perlite, Fesco Board Minimum ¾" thick	N/A	N/A

**Note:** Top layer of insulation shall be adhered with approved hot asphalt, within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as the base layer shall only be used as the base layer with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side face down.

**Base Sheet:** Install One ply of Arrowglass Base or MSA MG2 Base Sheet directly to the insulated substrate with a 4" lap. Adhere in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Ply Sheet:** Two or more plies of MSA Ply 4 or MSA Ply 6 ply sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to the base sheet.

**Surfacing:** Install the following:  
1. Flood coat of hot asphalt at an application rate of 60 lbs./sq.; plus gravel fully embedded at an application rate of 400 lbs./sq.

**Maximum Design Pressure:** -45 psf (See General Limitation #9.)



**Membrane Type:** BUR  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** 18-22 ga. steel  
**System Type C(1):** All layers of insulation simultaneously fastened.

**All General and System Limitations apply.**

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
ENRGY-3 Composite, ENRGY 3 Plus, ACFoam Composite, Thermaroom Composite-3, ISO 95+ Composite, Fesco Foam Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
EnergyGuard Perlite, Fesco Board Minimum ¾" thick	1, 4, 5, 9, 10, 11, 14, 16, 20, 21, 22, 23, 24, 25, 26, 27, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40	1:2 ft <sup>2</sup>

**Note:** All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Insulation fasteners shall be tested for withdrawal resistance in compliance with Testing Application Standard TAS 105 to confirm compliance with the wind load requirements. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

**Base Sheet:** Install One ply of Arrowglass Base or MSA MG2 Base Sheet directly to the insulated substrate with a 4" lap. Adhere in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Ply Sheet:** Two or more plies of MSA Ply 4 or MSA Ply 6 ply sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to the base sheet.

**Surfacing:** Install the following:  
 1. Flood coat of hot asphalt at an application rate of 60 lbs./sq.; plus gravel fully embedded at an application rate of 400 lbs./sq.

**Maximum Design Pressure:** -45 psf (See General Limitation #9.)



**Membrane Type:** BUR  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** 18-22 ga. steel  
**System Type D:** All layers of insulation and base sheet simultaneously attached to deck.

**All General and System Limitations apply.**

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
EnergyGuard Perlite, Fesco Board Minimum ¾" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
ACFoam II, Multi-Max FA-3, ISO 95+ GL Minimum 1.5" thick	N/A	N/A

**Note:** Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

**Base Sheet:** Install One ply of Arrowglass Base or MSA MG2 Base Sheet with fasteners spaced 18" o.c. in the 4" lap and in one row in the center of the sheet. Fasteners shall be as described below.

**Fastener: Option#1** Dekfast #12 Stainless Steel with 3" Round Plate; Dekfast #12, Dekfast #14, Dekfast #14 Stainless Steel with Lock or Hex Plate, Dekfast Autoset Plate; Dekfast #15 HS with Lock Plate; Dekfast Recessed Galvalume Steel Hex with #12 Hex Plate.

**Fastener: Option#2** Firestone All Purpose Fastener or HD Fastener with Hexagonal Plate.

**Fastener: Option#3** OMG #10, OMG Standard, OMG Heavy Duty, Stainless #12, Hex Head #12, Hex Head #14, Iron-Lok or Strap Toggle with Standard, G2 or OMG Plate; OMG Standard or Heavy Duty Fastener with OMG LGP Plate.

**Fastener: Option#4** Dekfast #12 DP, Dekfast #14, Dekfast #15 HS Fasteners with Dekfast Galvalume Steel 3" Round Plate; Dekfast System ES #12 Steel or Dekfast System ES #14 Steel.

**Fastener: Option#5** Trufast TP, DP, Ultra SS, HD, or DL Fasteners with MP-3 Plate; Trufast DP-H fastener with MPH-3 Plate; Trufast PA System.

**Ply Sheet:** Two or more plies of MSA Ply 4 or MSA Ply 6 ply sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to the base sheet.

**Surfacing:** Install the following:  
1. Flood coat of hot asphalt at an application rate of 60 lbs./sq.; plus gravel fully embedded at an application rate of 400 lbs./sq.

**Maximum Design Pressure:** -45 psf (See General Limitation #9.)



## STEEL DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117, calculations shall be signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.

## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

## END OF THIS ACCEPTANCE



NOA No: 15-0406.07  
Expiration Date: 02/09/17  
Approval Date: 01/28/16  
Page 12 of 12